

# *Certificate of Performance*

*On this date the cleanroom facilities of*

## *Oliver-Tolas Health Care Packaging*

*Have been tested in accordance with NEBB Procedural Standards for Certified Testing of Cleanrooms to meet the following air cleanliness classification requirements of International Standard ISO 14644-1 during the occupancy state noted.*

*Zone #6 Cleanroom - ISO Class 7 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest*

*Zone #6 Cleanroom - ISO Class 7 at 0.5 & 1.0  $\mu\text{m}$ – Operational*

*Zone #6 Gowning Area - ISO Class 7 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest*

*Zone #6 Gowning Area - ISO Class 7 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – Operational*

*NEBB Certified Firm: Air Filtration Management, Inc.*

*Phone: (610) 867-3869*

*www.airfiltrationmgmt.com*

*NEBB Certification Number: CR104*

*NEBB CPT Professional: William M. Bock*

*Signature: William M. Bock*

*Test Date: August 2011 Retest Date: February 2012*

**National Environmental Balancing Bureau**

